

MEMO

Boni•Maddison Architects

3732 West Broadway, Vancouver, B.C., V6R 2C1
Telephone (604) 688-5894, Fax (604) 688-5899
Email charlie@bonimaddison.com

TO: All Bidders

REFERENCE: Bid Call 1065-1065-0809/17
Office Renovations, 5485 Lane St., Burnaby, BC

FROM: Tatjana Gasic, IA AIBC Total pages 8

DATE: July 16, 2008

Addendum #2

This addendum amends information provided in the documents for this tender call. The information provided herein must be read and interpreted in conjunction with the written specifications, and the project drawings. The Contractor is responsible for including all costs associated with the work outlined in the addendum in the base Tender Price. The Contractor must also acknowledge receipt of this addendum when submitting the tender price.

- 1) The extent of lighting in the already occupied warehouse has not changed. See the attached electrical addendum which clarifies the revised power single line.
- 2) See attached mechanical addendum which clarifies the heating for the warehouse. An older Unit heater has been replaced with a tubular infrared heater and it will remain.
- 3) Request for alternates:
09650 Resilient Flooring, 2.2 Vinyl Flooring
We approve following Armstrong products:
 - Sheet Vinyl - Armstrong Royal
 - Sheet Vinyl – Armstrong Medintech
- 4) Request for alternates:
We approve following products:
 - Belanger Shower Valve Model 4110CP
 - Zurn Commercial Brass 4" Centreset Z81104
 - Onex Sink, Drop-In Double Bowl
- 5) Request for alternates:
102800 (10 28 00) Washroom Accessories
We approve following ASI Watrous Inc. products:
 - ASI/Watrous 0263-12/P Dispenser
 - ASI/Watrous 0215 Paper Towel Dispenser
 - ASI/Watrous 0620-B 24x36 Mirror
 - ASI/Watrous 3100 24x24x120 Degree Grab Bar

- ASI/Watrous 3101-Px24 Grab Bar

- 6) Ceramic wall tile located in rooms 105, 106, 107, 209 and 210 to be as per specifications. See the attached architectural drawing D3.4 which helps to clarify ceramic wall tile layout. Ceramic floor tile to be Olympia Tile, Winstone Series, Unglazed Porcelan Mosaics, 3"x3".
- 7) See hardware information on attached door schedule D2.2.
- 8) BC Housing will post all revised documents including those mentioned herein on the BC Housing website for download by the Contractor.
- 9) Contractor to acknowledge receipt of this addendum on the bid document tender form.

End of Addendum #2

Cc;

Owen Philip, BC Housing

Fax: 604-333-1908