

TECHNICAL BULLETIN NO. 16-2008

Note:

Date Issued: March 18, 2008
Subject : ASHRAE Standard 62.2 – Suite Ventilation



BC Housing

Reference: Provincial Homelessness Initiative Design Guidelines
& Construction Standards [^]

Page: 1 of 1

SUBJECT:

Suite Ventilation as described in Section 15550 Heating, Ventilation and Air Conditioning of the Provincial Homelessness Initiative Design Guidelines & Construction Standards.

PURPOSE:

To revise suite ventilation that is required to comply with ASHRAE Standard 62.2 "Ventilation for Acceptable Indoor Air Quality".

REFERENCE:

Provincial Homelessness Initiative Design Guidelines & Construction Standards, Section 15550 Heating, Ventilation and Air Conditioning.

DESCRIPTION:

Where smoking is permitted in suites BC Housing requires a minimum ventilation rate of 1.0 ACH to ensure that adequate indoor air quality and ventilation is maintained.

END